



**ISLAMIC UNIVERSITY OF SCIENCE & TECHNOLOGY  
AWANTIPORA, KASHMIR.**

Tele: 01933-247954/247955/247254; Website: www.islamicuniversity.edu.in.

### **CLARIFICATION**

It is notified for the information of all the concerned that the clarification regarding the Supply, Design, Fabrication , Testing & Commissioning of 630 KVA Distribution Transformer (DT) at IUST is as under:

**630 KVA ; Copper Wound ; 11000/440 Volt ; Oil Immersed Air Natural (ONAN) ; Three Phase ; Primary Delta/ Secondary Star type with neutral grounded ( Solid Grounding) ; Vector group - Dyn11 ; Step Down Distribution Transformer having Off Circuit Tap Changer (OCTC). Moreover all the relevant Standards (IS) amended up to date ment for Oil Filled Transformers are also applicable for this Transformer including Oil, Bushings, windings, Spares/ Enclosures , Fittings etc. Only Routine Tests needed.**

**Sd/-  
Superintendent Engineer**

**No: IUST/EW-ELE/Tend-Notice/440**

**Dated: 12-02-2018**